Sports Data Sheets **Netball**

Introduction

The following sports data sheets are for use in conjunction with Sport England's 'Developing the Right Sports Hall' (DRSH) main document. They relate to Step 5 'Establishing the Project Brief' and identify the needs of the priority sport and the key secondary sports.

These sheets show the requirements for Netball as the 'Priority Sport' at various levels of play and other 'Secondary Sports' that can fit into the same overall space.

	Level of Play											
New Level of Play Category ¹	International This category relates to the lowest level of International play ²	Premier This category relates a Premier / National League Club competing in regional or Inter county competitions	Club This category relates to a local club competing in District and County League competitions	Community This category relates to school and community use where there is no formal competitive structure / no specific need for space for officials or spectator accommodation								
Netball equivalent ³	International and Super League	Regional and Premier League	Local club and inter county competition	School and recreational use								

Commentary

The sports data sheets use the NGB's requirements for the field of play. The additional space requirements for officials are indicated separately as 'optional' for club and recreational levels of play. Spectators zones for match play are not included and are assumed to be a site specific requirement. For further details of the requirements for netball see the *Facilities and Court Information* available from England Netball's (EN) website: http://www.englandnetball.co.uk/the-game/Facilities_and_Courts and the 'Indoor Netball Facility Requirements' for International levels of play (Development section) from the International Federation of Netball Associations (IFNA) website http://www.netball.org. For further details of the requirements for 'secondary sports', see Appendix 8 of the main DRSH document for links to other NGB's websites.



Key Issues

- Spatial requirements: Netball practice can be played on all courts that are 30.5 x 15.25 m. When there is insufficient space for a full size court and full size run offs, then there should be a risk assessment to allow reduced run offs with the court being retained at 30.5 x 15.25 m.
- Court markings: For International and Premier levels of play, line markings to be white. For multi sport halls, where other line markings conflict, other colours can be used except yellow.
- Walls / Ceilings: Walls to be a dark colour and ceilings to be a light colour.
- Flooring: Goal posts to be secured in floor sockets complying with EN requirements. Floor fixings are only acceptable for retrofitting. Flooring to be area elastic category. End and side run-offs shall have the same surface as the playing area and be free of all permanent and temporary fixtures at court level and to a vertical height of 2.5m.
- Lighting: Uniformity ratio = Emin / eav. It is recommended that the system also allows lighting at 200 lux for training etc.
- Spectator Provision: There should be early consultation with England Netball on the spectator requirements for each project as these will vary from club to club and site to site.

Note: For further details see England Netball and IFNA websites and Sport England's design guidance notes 'Sports Halls Design and Layouts', 'Floors for Indoor Sports' and 'Artificial Sports Lighting'.

March Revision 001 1 © Sport England 2012

¹ New level of play categories for each sport as agreed by the NGBs and Sport England and applicable throughout this document.

² For higher levels of international competition, such as major championships, the relevant NGB should be consulted at a very early stage as the requirements vary considerably.

³ For other sports, see Appendix 4 'Level of play categories for each sport' within main document.

Sports Data Sheets **Netball**

Netball - Over	Source of inf	ormation:			http://www.englandnetball.co.uk/the-game/Facilities_and_Courts_and_http://www.netball.org_http://www.sportengland.org/facilities_planning/design_and_cost_guidance.aspx_							
International and Super League	Premier 23350 23350	Overall space (m) incl. R/O +	pace (m)			R	lun offs (r	n)	Additiona	l areas (m)	Specification	
23350 2000 21350 2000 Perimeter zone for TV cameras	2 350 21350 21350 er zone for TV cameras	T/O				R/O			T/O SS			
3050 15250 3050 service area will be required close to the competition court 10,000 service area will be required close to the competition court 10,000 service area will be required close to the competition court 10,000 service area will be required close to the competition court 10,000 service area will be required close to the competition court 10,000 service area will be required close to the competition court 10,000 service area will be required close to the competition court 10,000 service area will be required close to the court 10,000 service area will be required close to the court 10,000 service area will be required close to the competition court 10,000 service area will be required close to the competition court 10,000 service area will be required close to the competition court 10,000 service area will be required close to the competition court 10,000 service area will be required close to the competition court 10,000 service area will be required close to the competition court 10,000 service area will be required close to the competition court 10,000 service area will be required close to the competition court 10,000 service area will be required close to the court 10,000 service area will be required close to the court 10,000 service area will be required close to the court 10,000 service area will be required close to the court 10,000 service area will be required close to the court 10,000 service area will be required close to the court 10,000 service area will be required close to the court 10,000 service area will be required close to the court 10,000 service area will be required close to the court 10,000 service area will be required to the court 10,000 service area will be required to the court 10,000 service area will be required to the court 10,000 service area will be required to the court 10,000 service area will be required to the court 10,000 service area will be required to the court 10,000 service area will be required to the court 10,000 service area will be required to the court 1	3050 15250 3050 3050 3050 88	L x W x H	Length	Width	Height	Ends	Sides	Between courts / Between courts with a dividing net	Space for teams (T) and match officials (O)	Spectator seating	Flooring	Lighting
	dditional practice area	36.60 23.35 8.30 + TV zone	30.50	15.25	8.30	3.05	3.05	4.00 / 6.10	2.00 + additional perimeter zone for TV cameras	500 - 10000 seats	Any meeting IFNA standards	1500 lux 0.7 Emin / eav
Club 5 st	bipet to site specific ity foodcasting requirements	36.60 23.35 7.50	30.50	15.25	7.50	3.05	3.05	4.00 / 6.10	2.00	Optional	Any meeting AENA standards	750 lux 0.7 Emin / eav
3050 15250 3050 Perimet	er zone for TV cameras 1500 15250 1500 00 00 00 00 00 00 00 00 00 00 00 00	36.60 21.35 7.50	30.50	15.25	7.50	3.05	3.05	4.00 / 6.10	Optional	Optional	Any meeting AENA standards	750 lux 0.7 Emin / eav
9990	2000	34.50 18.25 7.50	30.50	15.25	7.50	2.00	1.50	3.00 / 3.00	Optional	Optional	Any meeting AENA standards	750 lux 0.7 Emin / eav

Sports Data Sheets **Netball**

Primary Sport

Netball http://www.englandnetball.co.uk/the-game/Facilities and Courts and http://www.netball.org Source of information: http://www.sportengland.org/facilities_planning/design_and_cost_guidance.aspx **International and Super League** 36.60 x 23.35 x 8.30 + additional perimeter zone for TV cameras Overall space (m) Principal playing area (m) Run offs (m) Additional areas (m) **Specification** Perimeter zone for TV cameras incl. R/O + Team / Officials T/O R/O T/O SS Additional practice area will be Additional practice area will be required close to the competition court Perimeter 3050 Perimeter zone for TV cameras Space for teams (T) and match officials (O) Between courts / Between courts with a dividing LX 30500 Spectator seating zone for TV cameras TV camera W x Lighting Flooring Length perimeter zone Height Width Sides Ends space allowances н subject to site specific broadcasting requirements 36.60 Any 1500 lux 500 -23.35 4.00 / meeting 10000 30.50 8.30 3.05 3.05 2.00 15.25 0.7 Emin / 8.30 +6.10 **IFNA** Perimeter zone for TV cameras seats eav TV zone* standards * Perimeter zone for TV cameras varies on a site by site basis and dimensions have not **Secondary Sports** been included (nominal allowance assumed for secondary sports court layouts) Sport Number Compliance Level 33.00 Combined. Lower 1.50 / 1.50 Badminton 4 court format Club 17.40 13.40 2.00 6.10 7.50 Optional Optional larea or mixed 2.60 (500 lux) 7.50 elastics 32.10 Semi-sprung Lower 4.10 / Basketball 20.10 1 court format Premier 28.00 15.00 7.00 2.05 2.05 1.00 Required wooden or 4.10 (500 lux) 7.00 synthetic 33.62 3.40 for Mats reg/d Lower Indoor Club / 5 lanes 23.70 31.62 1.00 (to ECB 3.66 7.70 1.00 basket -Cricket Community (750 lux) 7.70 ball goal standards) 0 court format Volleyball (lengthways) Volleyball disallowed - see 'Facility and Court Information' section from England Netball website for International and Super League courts: 'Note 6. Tennis post sockets and other equipment fixtures shall not be located within the playing area, side run offs or end run offs of the Netball court.' Volleyball 0 court format Training (transverse) Basketball Rings on side **Training** Training walls March Revision 001 © Sport England 2012

Sports Data Sheets **Netball**

Primary Sport / Secondary Sport Issues

Netball - International and Super League (cont/d)

Notes of key issues for international netball


- See 'Key Issues' on page 1 cover sheet.
- Hatched areas indicate space which is excess to secondary sport requirements. In some cases, this can provide improved circulation and space for spectators and wheelchair users.
- International levels of play for Netball have been based on the IFVA's requirements but including only a single court (in lieu of twin courts) in conjunction with an additional practice area close to the competition court. (not incorporated within this exercise). An additional perimeter zone for TV cameras is required and an indicative zone has been shown - however the extent of this zone varies on a site-by-site basis and dimensions
- have not been included. Therefore, only the court area, run-offs and officials areas have been included in the overall dimensions. The IFNA height requirements also exceed those for England Netball dedicated facilities.
- An England Netball accredited test laboratory shall survey and test the facility to ensure compliance with Category 5 Court Requirements within two months of construction and after any resurfacing works. The facility operator shall be responsible for commissioning the survey. Following the survey the laboratory will prepare a detailed report and copies will be sent to the facility operator and England Netball.
- To cater for young people's Netball (High Five Netball) and

- Wheelchair Netball, goal posts shall have adjustable net ring heights of 3.05 m,and 2.44 m.
- Tennis post sockets and other equipment fixtures shall not be located within the playing area, side run offs or end run offs of the Netball court.
- If space is limited, a common team bench area 1.5 m wide between adjacent courts may be provided i.e. a total of 4.5 m between courts.
- Line markings to be white.
- IFNA have further requirements for International events visit http://www.netball.org


Secondary Sports

Layouts for other sports within a dedicated international netball space of 36.60 x 23.35 x 8.30 m + additional perimeter zone for TV cameras


Badminton (Club)



Basketball (Premier)



Indoor Cricket



Volleyball (Premier) Volleyball Training

(transverse) - cannot be accommodated in an

Volleyball disallowed - see 'Facility and Court Information' section from England Netball website for International and Super League courts: 'Note 6. Tennis post sockets and other equipment fixtures shall not be located within the playing area, side run offs or end run offs of the Netball court.'

international netball space

Basketball Training

- can be
 accommodated
 in an
 International
 netball space
- number and location to project specific requirements

Sports Data Sheets **Netball**

Netba				Source of info	ormation:			http://www.englandnetball.co.uk/the-game/Facilities_and_Courts http://www.sportengland.org/facilities_planning/design_and_cost_guidance.aspx							
Premier	Overall space (m)	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1													
				incl. R/O +	Principal playing area (m)			Run offs (m) R/O			Additional	areas (m)	Specification		
Team / Officials			T/O	T/O SS											
3050 30500 3050 21350 C		L x W x H	Length	Width	Height	Ends	Sides	Between courts / Between courts with a dividing net	Space for teams (T) and match officials (O)	Spectator seating	Flooring	Lighting			
36600			36.60 23.35 7.50	30.50	15.25	7.50	3.05	3.05	4.00 / 6.10	2.00	Optional	Any meeting AENA standards	750 lux 0.7 Emin / eav		
Secondary	Secondary Sports														
Sport	Number	Compliance	Level												
Badminton	4 court format (including 1 dividing net)	✓	Club	33.00 17.40 7.50	13.40	6.10	7.50	2.00	1.50	1.50 / 2.60	Optional	Optional	Combined, area or mixed elastics	Lower (500 lux)	
Basketball	1 court format	~	Premier	32.10 20.10 7.00	28.00	15.00	7.00	2.05	2.05	4.10 / 4.10	1.00	Optional	Semi-sprung wooden or synthetic	Lower (500 lux)	
Indoor Cricket	4 lanes	~	Club / Community (Except height)	33.62 20.04 7.70	31.62	3.66	7.70	1.00	1.00	3.40 for basket - ball goal	-	-	Mats req/d (to ECB standards)	Same (750 lux)	
Volleyball	1 court format (lengthways)	(See overleaf)	Premier	28.00 17.00 7.50	18.00	9.00	7.50	5.00	3.00	6.00 / 6.00	2.00		Area elastic	Lower (500 lux)	
Volleyball Training	2 court format (transverse)	(See overleaf)	Training	30.00 20.00 7.50	18.00	9.00	7.50	1.00	3.00	6.00 / 6.00	N/A	N/A	Area elastic	Lower (500 lux)	
Basketball Training	Rings on side walls	/	Training												
March Revision	001					5							© Sport Engl	and 2012	

Sports Data Sheets **Netball**

Primary Sport / Secondary Sport Issues

Netball - Premier (cont/d)

Notes of key issues for premier netball

- See 'Key Issues' on page 1 cover sheet.
- Hatched areas indicate space which is excess to secondary sport requirements. In some cases, this can provide improved circulation and space for spectators and wheelchair users.
- Premier Netball requires a warm-up netball court. However, it
 is not mandatory that this warm-up hall requires being close
 to the competition court (as in for International level of play
 and as set out in the AENA regulation requirements) and can
 be located remotely from the main competion hall. Therefore,
 a single court hall has been included for this level of play.
- An England Netball accredited test laboratory shall survey and test the facility to ensure compliance with Category 5 Court Requirements within two months of construction and after any resurfacing works (see Notes on page 1 cover sheet).
- To cater for young people's Netball (High Five Netball) and Wheelchair Netball, goal posts shall have adjustable net ring heights of 3.05 m, and 2.44 m.
- Values shall be measured on the playing surface. Measurements shall be made on a 5 m grid over the court area.
- The facility operator shall be responsible for commissioning the survey. Following the survey the laboratory will prepare a

- detailed report and copies will be sent to the facility operator and England Netball.
- Tennis and other post sockets shall not be located within the playing area, side run offs or end run offs of the Netball court. However some sports equipment, such as volleyball net posts safely secured using appropriate base plates with weights / floor fixings, may be incorporated subject to approval with England Netball / NGB.
- Line markings to be white.
- AENA have further requirements for Premier (National) events - see http://www.englandnetball.co.uk

Secondary Sports

Layouts for other sports within a dedicated premier netball space of 36.60 x 23.35 x 7.50 m

Badminton (Club)

Basketball (Premier)

20100

راه)


15000

2050

1000 2050


2050

Indoor Cricket




Volleyball (Premier)

(See conditions above)



Volleyball/Basketball Training (transverse)

(See conditions above)



Sports Data Sheets **Netball**

Netba				Source of info	ormation:			http://www.englandnetball.co.uk/the-game/Facilities_and_Courts http://www.sportengland.org/facilities_planning/design_and_cost_guidance.aspx							
Club			Overall space (m)	1											
ļ	incl. R/O	Principal playing area (m)			Run offs (m) R/O			Additiona	l areas (m)	Specifi	cation				
3050									T/O SS						
30500 30500 3050 O 15250		L x W x H	Length	Width	Height	Ends	Sides	Between courts / Between courts with a dividing net	Space for teams (T) and match officials (O)	Spectator seating	Flooring	Lighting			
36600				36.60 21.35 7.50	30.50	15.25	7.50	3.05	3.05	4.00 / 6.10	Optional	Optional	Any meeting AENA standards	750 lux 0.7 Emin / eav	
Secondary	Secondary Sports														
Sport	Number	Compliance	Level												
Badminton	4 court format	~	Club	31.90 17.40 7.50	13.40	6.10	7.50	2.00	1.50	1.50 / 2.60	-	-	Combined, area or mixed elastics	Lower (500 lux)	
Basketball	1 court format	~	Club	32.10 20.10 7.00	28.00	15.00	7.00	2.05	2.05	4.10 / 4.10	1.00	Optional	Semi-sprung wooden or synthetic	Lower (500 lux)	
Indoor Cricket	3 lanes	(Except height)	Club / Community	33.62 20.04 7.70	31.62	3.66	7.70	1.00	1.00	3.40 for basket - ball goal	-	-	Mats req/d (to ECB standards)	Same (750 lux)	
Volleyball	1 court format (lengthways)	✓	Premier	28.00 17.00 7.50	18.00	9.00	7.50	5.00	3.00	6.00 / 6.00	2.00	-	Area elastic	Lower (500 lux)	
Volleyball Training	2 court format (transverse)	✓	Training	30.00 20.00 7.50	18.00	9.00	7.50	1.00	3.00	6.00 / 6.00	N/A	N/A	Area elastic	Lower (500 lux)	
Basketball Training	Rings on side walls	/	Training	-											
March Revision	001					7							© Sport Engl	and 2012	

Sports Data Sheets **Netball**

Primary Sport / Secondary Sport Issues

Netball - Club (cont/d)


Notes of key issues for club netball

- See 'Key Issues' on page 1 cover sheet.
- Hatched areas indicate space which is excess to secondary sport requirements. In some cases, this can provide improved circulation and space for spectators and wheelchair users.
- An England Netball accredited test laboratory shall survey and test the facility to ensure compliance with Category 3 Court Requirements within two months of construction and after any resurfacing works.
- End run-offs and side run-offs shall have the same surface as the playing area. They shall be free of all permanent and temporary fixtures at court level and to a vertical height of 2.5 m.
- To cater for young people's Netball (High Five Netball) and Wheelchair Netball, goal posts shall have adjustable net ring heights of 3.05 m, 2.75 m and 2.44 m. The values shall be measured on the playing surface. Measurements shall be made on a 5 m grid over the court area.
- The safety margins indicated between the cricket practice nets and walls are higher (indicative dimensions indicated) than the minimum required to allow for the basketball training courts with retractable goals fitted to the side walls - see the ECB TS3 document for further advice on recommended clearances.
- Basketball practice rings can be related to the volleyball training court (see diagram below for Volleyball / Basketball training) or placed independently without any specific court markings.


Secondary Sports

Layouts for other sports within a club netball space of 36.60 x 21.35 x 7.50 m


Badminton (Club)




Basketball (Club)




Indoor Cricket



Volleyball (Premier)



Volleyball/Basketball Training (transverse)



Sports Data Sheets **Netball**

Netba				Source of info	urce of information: http://www.englandnetball.co.uk/the-game/Facilities_and_Courts http://www.sportengland.org/facilities_planning/design_and_cost_guidance.aspx									
Community	у			Overall										
	space (m) incl. R/O +	Principa	Principal playing area (m)			Run offs (m)			l areas (m)	Specification				
			T/O				R/O			T/O SS				
2000 30500 2000 0 15250			L x W x H	Length	Width	Height	Ends	Sides	Between courts / Between courts with a dividing net	Space for teams (T) and match officials (O)	Spectator seating	Flooring	Lighting	
34500				34.50 18.25 7.50	30.50	15.25	7.50	2.00	1.50	3.00 / 3.00	Optional	Optional	Any meeting AENA standards	750 lux 0.7 Emin / eav
Secondary Sports														
Sport	Number	Compliance	Level											
Badminton	4 court format	✓	Club	31.90 17.40 7.50	13.40	6.10	7.50	2.00	1.50	1.50 / 2.60	-	-	Combined, area or mixed elastics	Lower (500 lux)
Basketball	0 court format	X	Community	32.10 19.10 7.00	28.00	15.00	7.00	2.05	2.05	4.10 / 4.10	-	-	Semi-sprung wooden or synthetic	Lower (500 lux)
Indoor Cricket	2 lanes	(Except height)	Club / Community	33.62 12.72 7.70	31.62	3.66	7.70	1.00	1.00	3.40 for basket - ball goal	-	-	Mats req/d (to ECB standards)	Same (750 lux)
Volleyball	1 court format (lengthways)	✓	Premier	28.00 17.00 7.50	18.00	9.00	7.50	5.00	3.00	6.00 / 6.00	2.00	-	Area elastic	Lower (500 lux)
Volleyball Training	0 court format (transverse)	X	Training	20.00 15.00 7.50	18.00	9.00	7.50	1.00	3.00	6.00 / 6.00	N/A	N/A	Area elastic	Lower (500 lux)
Basketball Training	Rings on side walls	~	Training	-										
March Revision	001					9							© Sport Engl	and 2012

Sports Data Sheets **Netball**

Primary Sport / Secondary Sport Issues

Netball - Community (cont/d)

Notes of key issues for community netball


- See 'Key Issues' on page 1 cover sheet.
- Hatched areas indicate space which is excess to secondary sport requirements. In some cases, this can provide improved circulation and space for spectators and wheelchair users.
- The community netball court shown at 34.5 x 18.25 m with 2.0 m run off at ends and 1.5 m to the sides is the minimum size recommended by England Netball.
- For a community netball court located within a 34.5 x 20 m sports hall, the court should be offset to give a 1.75 m

- margin on one side with 1.5 m side run offs.
- End run-offs and side run offs shall have the same surface as the playing area. They shall be free of all permanent and temporary fixtures at court level and to a vertical height of 2.5 m.
- To cater for young people's Netball (High Five Netball) and Wheelchair Netball, goal posts shall have adjustable net ring heights of 3.05 m, 2.75 m and 2.44 m. The values shall be measured on the playing surface. Measurements shall be made on a 5 m grid over the court area.
- The minimum safety margins indicated between the cricket practice nets and walls should be increased if basketball training rings are fitted to the side walls - see the ECB TS3 document for further advice on recommended clearances.

Secondary Sports

Layouts for other sports within a community netball space of 34.50 x 18.25 x 7.50 m


Badminton (Club)



Basketball (Community)

- cannot be
accommodated in a
community netball
space, unless it is made
wider or if side margins
are reduced subject to
risk assessment

Indoor Cricket



Volleyball (Premier)

- cannot be
accommodated in a
community netball
space, unless it is
made wider

Volleyball Training (transverse)

- can be
n a accommodated in a
ll community netball
s space

Basketball

Training

 number and location to project specific requirements

March Revision 001 10 © Sport England 2012